



# INCERT CERTIFICATE

## C-026-1499



Issued 25-05-2021 Replaces  
Expiry date 25-05-2027 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: P15-W Capture Wireless Dual PW 868Mhz  
Trademark: Capture  
Type designation: GDAA1000  
Serial No: N/A  
Hardware / Software: GDAA1000 / FIR0181-1.1, FIR0172-2.8

Placed on the market under the name or trademark of:

Name of the manufacturer: Texecom Ltd.  
Address: St. Crispin Way  
City: BB4 4PW HASLINGDEN  
Country: United Kingdom of Great Britain and Northern Ireland

This certificate is granted to:

Name of the certificate holder: Texecom Ltd.  
Address: St. Crispin Way  
City: BB4 4PW HASLINGDEN  
Country: United Kingdom of Great Britain and Northern Ireland

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

# CERTIFICATE

Telefication B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Category: PIR detector  
Security grade: 2  
Environmental class: II  
Equipment class: Wireless

Factory location:  
Texecom Ltd  
St Crispin Way  
BB4 4PW, Haslingden  
United Kingdom

Product inspection location:  
JCL Logistics Benelux B.V.  
Everdenberg 14  
Oosterhout  
The Netherland

**Documentation lodged for this INCERT certificate**

Test Reports:

- Telefication B.V.: 200202006-001-Ver. 2.00, 21 May 2021
- Element Materials Technology Warwick Ltd.: TSR-TRA-045950-35-07A\_1\_\_EMC Capture CD-W, D15-W \_ QD-W TRA-045950-35-07A\_\_Doc\_, 12 March 2020
- Telefication B.V.: 200202006-002-Ver. 2.00, 21 May 2021

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1 February, 2018

**Applied Standards**

EN 50130-5	June, 2011
EN 50131-5-3	March, 2017
EN 50131-6	October, 2017
EN 50131-2-2	November, 2017
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2	May, 2017

**The product as described in this certificate includes the following type designations**

- Product description: P15-W Capture Wireless Dual PW 868Mhz
- Trademark: Capture
- Type designation: GDAA1000
- Hardware version: GDAA1000
- Software version: FIR0181-1.1, FIR0172-2.8
- Serial number: N/A